

Your Lead Line Replacement is Complete!

Lead on customer side?

☐ YES ☐ NO

Water Distribution

replacelead@toledo.oh.gov
419-936-2826



Flush First

Immediately turn on every tap in your home and let them run for 30 minutes. This cleans out any contaminants stirred up during construction.

Test Your Water

1. **Wait until you haven't used your water for at least 6 hours**, such as in the morning when you first wake up.
 2. **Use cold water from your faucet**, do not run water through a filter or aerator.
 3. **Fill the sample bottle to the line marked "1000-mL"** then cap the bottle tightly.
 4. **Fill out the label on the sample bottle**, making sure it is complete and accurate.
 5. **Leave the bottle on your door step**, city workers will be back to collect the sample on:
-
6. **Results will be delivered to your door in 30 days.** You will be required to resample if lead is present.

Filter Your Water

1. **Install the Brita filter onto your kitchen faucet**, or the one you use for drinking and cooking. No need to filter water used for bathing or cleaning.
2. **Insert the filter cartridge into the filter cup until you hear it click**, do not force.
3. **A green signal will flash**, then flush the filter with cold water for 5 minutes.
4. **Continue to use the filter as long as you like**, it's yours to keep at no cost.

More Information

City of Toledo

toledo.oh.gov/lead-service-lines

Ohio EPA

epa.gov/safewater/lead

Brita Filter System

Model SAFF-100, FR-200 Cartridge